

(Translation)

No. CS059/2020

November 27, 2020

Subject: Notification of the fire incident at a sugar mill plant of Khon Kaen Sugar Industry Public Company Limited

To:

President

The Stock Exchange of Thailand

Khon Kaen Sugar Industry Public Company Limited ("the Company") would like to inform that on November 19, 2020 around 20.30 p.m. There was a fire incident caused by a short circuit at roller mill No.2 building at a Company's plant located at Nampong district Khon Kaen province. The fire was completely extinguished by 22:30 p.m. and no people were injured in this incident.

After the survey, Turbine No 1-6 and power cable was found slightly damaged. The damage was covered with insurance. The incident does not affect the production and operation of the company. At present, the company still operates normally.

Please be informed accordingly.

Yours sincerely,

(-Signature-)

Mr. Chamroon Chinthammit

Chief Executive Officer and President

Khon Kaen Sugar Industry Public Company Limited

Company Secretary and Legal Office

Telephone: 02 642-6230 Facsimile: 02 642-6092

-สำนักงานใหญ่ : อาการ เค.เอส.แอล. ทาวเวอร์ ชั้น 9 เลชที่ 503 ถนนสรีอยุธยา แขวงถนนพญาไท เชตราชเทวี กรุงเทพฯ 10400 โทร. (02) 6426191-200 แฟกซ์ (02) 6426097

HEAD OFFICE : 503 KSL TOWER, 9FL, SRIAYUDHYA RD, PHAYA THAI ROAD SUB-DISTRICT, RATCHATHEWI DISTRICT, BANGKOK, 10400 THAILAND TEL. (682) 6426191-200 FAX : (682) 6426097 กะเบียนเอนที่ บมจ. 0107547000214 PUBLIC COMPANY REG. NO. 0107547000214

